

GENERAL NOTES

REV. I

**THE FOLLOWING IS TO BE PROVIDED BY THE PURCHASER
AND/OR CONTRACTOR UNLESS OTHERWISE SPECIFIED.**

- 1) ELEVATOR TO BE CONSTRUCTED IN ACCORDANCE WITH ASME A17.1 PART 5.3 AND ALL LOCAL CODES.
- 2) ELECTRICAL REQUIREMENTS ARE BY OTHERS AS FOLLOWS:
SAFETY SWITCH EXAMPLE: "SQUARE D" -- CAT# D-322N OR H-322N
-3 POLE DISCONNECT SWITCH
-230 VAC 40 AMP CIRCUIT 1 PHASE FUSED WITH 35 AMP DUAL ELEMENT TIME DELAY (EX. RK1, RK5, J, CC)
CLASS FUSE WITH GROUND AND NEUTRAL TO BE INSTALLED IN A LOCKABLE FUSED DISCONNECT. (DEDICATED CIRCUIT)
(208 VOLT 1 PHASE REQUIRES A BUCK BOOST TRANSFORMER)
-120 VAC 15 AMP CIRCUIT 1 PHASE WITH 15 AMP PROTECTION. (DEDICATED CIRCUIT)
- 3) IT IS RECOMMENDED FOR A MINIMUM OF ONE HOISTWAY DOOR, ENTRANCE, AND ASSOCIATED FRAMING TO BE LEFT UNFINISHED UNTIL THE ELEVATOR IS SET IN PLACE. CHECK WITH LOCAL DEALER FOR PREFERENCE.
- 4) HOISTWAY MUST BE PLUMB WITHIN 1/8 INCH PER 10 FT OF HEIGHT AND SQUARE AT ANY POINT WITHIN 1/4 INCH BASED ON DIFFERENCE IN DIAGONAL MEASUREMENTS.
- 5) MACHINE ROOM MUST BE PROVIDED FOR THE OPERATING EQUIPMENT THAT MEETS N.E.C. CLEAR SPACE REQUIREMENTS AND ALL LOCAL CODES. MACHINE ROOM MUST HAVE A LIGHT AND A CONVENIENCE OUTLET. TEMPERATURE IN HOISTWAY AND MACHINE ROOM TO BE MAINTAINED BETWEEN 60-110° F AND RELATIVE HUMIDITY SHOULD NOT EXCEED 95%.
- 6) CODE REQUIRES A TELEPHONE CONNECTION TO THE ELEVATOR CAR THEREFORE, A PHONE LINE MUST BE INSTALLED IN THE MACHINE ROOM.
- 7) ALL HOISTWAY DOORS REQUIRE AN INTERLOCK, DOOR HANDLE, AND LATCH SET.
NOTE : A buildout/spaceguard on the door may be needed to meet required clearances.
- 8) ANY ALTERATIONS TO THE EQUIPMENT WITHOUT WRITTEN AUTHORIZATION BY WAUPACA ELEVATOR WILL VOID ALL WARRANTIES.
- 9) STRUCTURE MUST BE CAPABLE OF SUPPORTING THE APPROPRIATE LOADS. LOCAL ENGINEERING SUPPORT IS RECOMMENDED.
- 10) WHEN USED, CONCRETE MUST BE A MINIMUM OF 4" THICK 3500 PSI.
- 11) NOMINAL DEAD(STATIC) LOAD OF ELEVATOR IS 800 LBS. THIS INCLUDES SLING, CAB, FLOORING, GATE(S), ETC. AND ALL PERMANENT FIXTURES.

General Specifications

Series:	Paca-Ryde J-Type Rail	Speed:	Nominal 40 ft/min (0.20 m/s)
Rated Load (Capacity):	1000 lb / 453.6 kg	Logic:	STANDARD
Motor:	3.5 HP STARTING AMPS: 84 FLA: 24.6 LRA: 84		
Controller:	230V 1 PH AC 60 HZ AMP: 26.8		
Size: 24" x 18" x 8"	Circuit: 40 AMP	Fuse: 35 AMP	
Cab Light Circuit: 120V 15 AMP	Oil Line Pipe: 3/4" Schedule 80		
Shut Off Valve Pressure Rating:	1265 psi / 87.2 bar		
Maximum Working Pressure:	740 psi / 51 bar		5.5 GPM / 20.8 LPM
Cable:	(2) 3/8" 8-19 Traction Steel		
Cab Emergency Light/Alarm Bell: Standard	Gate Weight:	52 lbs.	
Hoistway Door Interlocks:		Travel:	
Cab Size:		# of Stops:	
Cab Model:			

Jack Specifications

Outer diameter of the piston	80mm / 3.15in
Piston wall thickness	7.5mm / .295in.
Outer diameter of the cylinder	101.6mm / 4in
Cylinder wall thickness	3.6mm / .142in
Cylinder head outer diameter	150mm / 5.91in
Head thickness	20mm / .787in



ELEVATOR CONTRACTOR:			
JOB NAME:		ORDER NUMBER:	
HYDRAULIC ELEVATOR NOTES & SPECIFICATIONS			
DRAWN BY:	DATE:	SIGNATURE OF APPROVAL	DWG. NO. C-003038